



OPEN ACCESS



Operations Research and Decisions

www.ord.pwr.edu.pl

OPERATIONS  
RESEARCH  
AND DECISIONS  
QUARTERLY



# Supervisory optimal control using machine learning for building thermal comfort

Shokhjakhon Abdufattokhov\*<sup>1</sup>  Nurilla Mahamatov<sup>1</sup>  Kamila Ibragimova<sup>2</sup>  
Dilfuza Gulyamova<sup>2</sup> Dilyorjon Yuldashev<sup>1</sup>

<sup>1</sup>Department of Automatic Control and Computer Engineering, Turin Polytechnic University in Tashkent, Tashkent, Uzbekistan

<sup>2</sup>Department of Computer Engineering, Tashkent University of Information Technologies, Tashkent, Uzbekistan

\*Corresponding author: [sh.abdufattohov@polito.uz](mailto:sh.abdufattohov@polito.uz)

## Abstract

For the past few decades, control and building engineering communities have been focusing on thermal comfort as a key factor in designing sustainable building evaluation methods and tools. However, estimating the indoor air temperature of buildings is a complicated task due to the nonlinear and complex building dynamics characterised by the time-varying environment with disturbances. The primary focus of this paper is designing a predictive and probabilistic room temperature model of buildings using Gaussian processes (GPs) and incorporating it into model predictive control (MPC) to minimise energy consumption and provide thermal comfort satisfaction. The full probabilistic capabilities of GPs are exploited from two perspectives: the mean prediction is used for the room temperature model, while the uncertainty is involved in the MPC objective not to lose the desired performance and design a robust controller. We illustrated the potential of the proposed method in a numerical example with simulation results.

**Keywords:** *building thermal comfort, Gaussian processes, machine learning, model predictive control*

## 1. Introduction

Due to the disintegrated character of the building dynamics in terms of optimisation and control, achieving an energy-efficient building climate control scheme that integrates fully automated heating, ventilation, and air conditioning (HVAC) services is still an open question. In building climate control problems, HVAC systems keep room temperature within a comfortable range. For decades, thermal comfort has been considered an aspect of a sustainable building in almost all sustainable building evaluation methods and tools [16, 18]. Because estimation errors based on inaccurate models or incorrectly estimated disturbances result in more energy and cost demand with customer-defined high comfort. Predictive control in building applications has the potential to be more energy and cost-effective than non-predictive control,

Received 1 December 2021, accepted 12 December 2022, published online 8 February 2023

ISSN 2391-6060 (Online)/© 2022 Authors

The costs of publishing this issue have been cofinanced by the program *Development of Academic Journals* of the Polish Ministry of Education and Science under agreement No. RCN/SP/0241/2021/1

where the commanded system has unique storage properties such as limits for the controlled variables instead of single set points, future disturbances of the controlled system that are known or can be predicted by the controller and the corresponding time-dependent costs for control actions depending on variables that are known or can be forecast [17]. In particular, building system applications with means for low and high-cost heating and cooling are potentially rewarding when using predictive control. Since conditions mentioned above are usually fulfilled for thermal control of buildings, many specific predictive control applications in building systems have been investigated [19, 28]. However, estimating the indoor air temperature of buildings is a complicated task due to the HVAC system's nonlinear and complex dynamic characterised by the time-varying environment with disturbances. Developing the building model is the most primary and time-consuming task when the modelling technique relies on physics-based and grey-box methods [25] based on energy and mass balance integral–differential equations. On the other hand, the rapid development of machine learning (ML) techniques and the increasing data accessibility in buildings have empowered the study of data-driven building models due to their simplicity, high level of automation, and low development engineering effort.

Building climate control must balance three conflicting demands such as energy efficiency, cost and thermal comfort. One possible approach is the quality and quantity parameters tuning to optimise the system performance from the online decoupling control method with variable flow rates. The authors of [37] proposed an event-driven optimisation mechanism with adaptive intervals that can take necessary optimisation actions for the system while considering delayed response characteristics. However, this study has some restrictions in providing optimal solutions for real-time with a low computational burden. In addition, fixed thresholds in this study may border the adaptability to climate variations.

Model predictive control (MPC) is an optimal control method to design control law by minimising a performance index while handling these demands. MPC has been implemented successfully in several directions of building control and operation strategies [4, 29]. Better thermal comfort and more energy savings compared to other control techniques can be achieved by combining MPC and ML such as neural networks [26], random forest [33], support vector machines [39]. However, designing accurate building energy/temperature models is the cornerstone to developing MPC for whole building operation and control due to the presence of external disturbances. The performance of the proposed control strategy may deviate from expectations, especially when the model is insufficient to accurately capture the building's thermal dynamics and there is a significant deviation. These problems limit the practical application of model-based control methods for HVAC system control to a certain extent. This issue can be alleviated by modelling the building dynamics using Gaussian processes (GPs) since it also measures the uncertainty bounds. Unfortunately, most GPs-based control laws do not take advantage of this information [2, 22]. The main focus of this paper is designing a predictive and probabilistic room temperature model of buildings using GPs. We exploit the GP's full probabilistic capabilities as the mean prediction for the room temperature model and use the model uncertainty in the MPC objective function not to lose the desired performance and to design a robust controller.

The remainder of this paper is organised as follows: Section 2 starts with a comprehensive review of literature related to the proposed methodology and is followed by Section 3, which provides the preliminary background and framework for data preparation. A methodology for constructing a predictive and probabilistic building model using GPs is discussed in Section 4, while Section 5 deals with theoretic-

cal analysis of designing a supervisory control combining GPs with MPC scheme to solve the building climate control problem. Afterwards, the potentials of the proposed control scheme are demonstrated in simulation with some numerical results in Section 6. Finally, the conclusions of our work are drawn, and further research challenges are discussed in Section 7.

## 2. Related work

In these circumstances, several research works have been investigated considering the time-varying user comfort preference [20]. Optimised energy and comfort management scheme for intelligent and sustainable buildings is provided in [1, 32]. A comprehensive review focusing on thermal comfort predictive models and their applicability for energy control purposes is analysed in [12]. Authors in [9] use multiple linear regression algorithm-based tools for predicting and controlling occupant thermal comfort using the predicted mean vote model. The efficiency of their algorithm to discover the best configuration parameters is shown to improve the thermal comfort of indoor occupants. In [10], authors build a new model that uses a deep neural network to predict the indoor temperature comfort in real-time of people belonging to different disability categories. They use a new Internet of Things (IoT) architecture to create their real-world data set. The architecture allows relevant data to be collected before being transferred to cloud servers for further analysis to manage intelligent thermal comfort. In [15], several standard ML algorithms are used to create a new human thermal comfort sense model data obtained from HVAC system of buildings in the summer and winter. The model picks the optimum feature set that may be utilised to predict thermal comfort and balance data with fewer samples. According to the authors in [23], the recommended approach for looping the split air-conditioning system leads to pre-emptive control of the occupants' thermal comfort based on the HVAC temperature set point. In order to develop comfort models, the neighbourhood component analysis feature selection approach is used to automatically discover the best characteristics through a Bayesian-optimisation-algorithm-based artificial-neural network to construct a prediction model for the thermal indices. A model-free approach, Deep Q-learning based multi-objective optimal control strategy for real-time reset of supply air temperature and chilled supply water temperature set point in a multi-zone building variable air volume system is designed in [13]. Nevertheless, these approaches lack the robustness to uncertainties introduced to the system. A nonlinear MPC strategy to optimise low-energy office buildings' heating and cooling modes is investigated in [31], where the robustness of MPC over the classical rule-based control scheme is proven. A random forest regression-based data-driven modelling approach for MPC is introduced in [33] to handle uncertainties in building dynamics. However, these papers neither provide theoretical guarantees for robust stability nor involve real-time disturbances affecting the thermal building model.

In this paper, the primary residential building model that reproduces the buildings' essential static and dynamic thermal properties is approximated by GPs. This data-driven model is employed to explore the potential of predictive control for integrated room automation. The room temperature is controlled within a defined comfort range to satisfy the thermal comfort demand. This is achieved by a GPs-based MPC strategy that calculates an optimal future profile of the manipulated variables while constraints on the manipulated variables and estimated disturbances are considered in real-time.

### 3. Data preparation

#### 3.1. Data acquisition

To provide thermal comfort in buildings, HVAC systems are usually manipulated to keep room temperature within a comfortable range. However, designing a proper controller to minimise cost in the building system while preserving thermal comfort is a challenging task due to the HVAC system's complex dynamic characteristics, uncertain and time-varying environment, and disturbances. For this reason, the data acquisition system, e.g., supervisory control and data acquisition (SCADA) has to be set up in such a way that the gathered data should comprise information both from inside (power consumption, water flow and water temperature, human occupation, carbon dioxide level, etc.) and outside (air temperature, air humidity, solar radiation, outside wall temperature, wind speed, etc.) the building. One option to correlate these features is to employ nonlinear autoregressive exogenous (NARX) model architecture [22] that incorporates historical information up to a certain lag order. Then a training data set  $\mathbf{D}$  of  $N$  samples consisting of input–output pairs  $\mathbf{D} = \{\mathbf{X}_{l_y;l_u;l_d}; \mathbf{Y}\}$  is collected as  $\mathbf{X}_{l_y;l_u;l_d} = [\mathbf{x}_1; \mathbf{x}_2; \dots; \mathbf{x}_N]_{l_y;l_u;l_d}$  and  $\mathbf{Y} = [\mathbf{y}_1; \mathbf{y}_2; \dots; \mathbf{y}_N]$  with

$$\mathbf{x}_i = [\mathbf{y}_i(l_y) \quad \mathbf{u}_i(l_u) \quad \mathbf{d}_i(l_d)] = \begin{cases} \mathbf{y}_i(l_y) = [\mathcal{Y}_{i-1}^j; \dots; \mathcal{Y}_i^j]; & j = 1; 2; \dots; N_r \\ \mathbf{u}_i(l_u) = [\mathcal{U}_{i-1}^k; \dots; \mathcal{U}_i^k]; & k = 1; 2; \dots; N_u \\ \mathbf{d}_i(l_d) = [\mathcal{D}_i^h; \dots; \mathcal{D}_i^h]; & h = 1; 2; \dots; N_d \end{cases} \quad (1)$$

where  $\mathbf{y} \in \mathbb{R}^{n_y}$  is power/temperature measurement vector,  $\mathbf{u} \in \mathbb{R}^{n_u}$  is heating/cooling set-point vector,  $\mathbf{d} \in \mathbb{R}^{n_d}$  is external disturbance vector affecting to the building dynamics,  $N_r \in \mathbb{R}$  is the total number of rooms,  $N_u \in \mathbb{R}$  is the total number of control inputs,  $N_d \in \mathbb{R}$  is the total number of disturbance parameters, and  $l_y, l_u, l_d \in \mathbb{R}$  are corresponding minimal auto-regressive lags to be determined by feature selection algorithms as we discuss next.

#### 3.2. Feature selection

The feature selection process is one of the most critical steps in prediction problems since it finds the smallest subset that significantly affects the prediction accuracy and minimises the model's complexity. The accuracy of the prediction model dramatically depends on the quality of data and the relevancy of features. A review paper [40] summarises feature selection applications in building energy management, including filter method [27], wrapper method [21], and embedded method [24]. However, these methods are very general and quite conservative in terms of learning speed. We adopt the algorithm proposed in [35] to select the minimum lag orders to get the most informative features by maximising the relevancy of the features on the buildings' load consumption and thermal comfort settings.

## 4. Learning building model with Gaussian processes

**Definition 1.** Gaussian processes is an assembly of stochastic variables that any finite collection of these variables follows a multivariate normal distribution over functions with a continuous domain.

The Bayesian inference of continuous variables leads to GPs regression where the prior GPs model is updated with a training data set to obtain a posterior GPs distribution [36]. Due to the possibility of including prior knowledge making the method more attractive compared to other regression algorithms, GPs models have been employed in different research fields [7, 34, 38]. This section provides the necessary background about GPs and framework to build a probabilistic and predictive model for regression problems mainly, adopted from [3, 30].

#### 4.1. Probabilistic model

Let a triple  $(\mathcal{X}; \mathcal{A}; \mathcal{P})$  describe a probability space consisting of sample space  $\mathcal{X}$ , corresponding  $\mathcal{A}$ -algebra and the probability measure  $\mathcal{P}$ . Then a stochastic process can be expressed by a measurable function  $f_{GP}(\mathbf{x})$  in  $\mathcal{X} \subseteq \mathcal{R}^n$ , which is fully described by the mean function  $\mu: \mathcal{X} \rightarrow \mathcal{R}$  and covariance function  $\Sigma: \mathcal{X} \times \mathcal{X} \rightarrow \mathcal{R}$  such that

$$f_{GP}(\mathbf{x}) \sim \mathcal{GP}(\mu(\mathbf{x}); \Sigma(\mathbf{x}; \mathbf{x}^\theta)) \quad (2)$$

$$\mu(\mathbf{x}) = E[f_{GP}(\mathbf{x})] \quad (3)$$

$$\Sigma(\mathbf{x}; \mathbf{x}^\theta) = E[(f_{GP}(\mathbf{x}) - \mu(\mathbf{x}))(f_{GP}(\mathbf{x}^\theta) - \mu(\mathbf{x}^\theta))] \quad (4)$$

with pair  $(\mathbf{x}; \mathbf{x}^\theta) \in \mathcal{X}$ . The mean function of the  $\mathcal{GP}$  distribution illustrates the point where the samples are more likely located, while the variance of the  $\mathcal{GP}$  distribution comes from measuring the correlation of any two samples  $(\mathbf{x}; \mathbf{x}^\theta)$  that is calculated by the covariance function. We refer to [30] for a variety of mean and covariance functions.

Despite the absence of the existence of the probability density function of the GPs, their finite collection follows multivariate Gaussian distribution. This property allows us to write samples as a joint multivariate Gaussian distribution with a mean  $\mu$  and variance  $\Sigma$  such that

$$\mathbf{y}_i = f_{GP}(\mathbf{x}_i) \sim \mathcal{GP}(\mu(\mathbf{x}_i); \Sigma(\mathbf{x}_i | \mathbf{ig})); \quad i = 1; 2; \dots; N; \quad (5)$$

where  $\mathbf{ig} \in \mathcal{R}^n$  is a set of prior (initial guess) parameters of mean and covariance functions.

#### 4.2. Model learning

Maximum likelihood is a commonly used optimisation method in the Bayesian framework and its conditional probability function on training input samples  $\mathbf{X}$  together with parameters  $\theta$  is defined as follows

$$\mathcal{P}(\mathbf{Y} | \mathbf{X}; \theta) = \frac{1}{(2\pi)^{\frac{N}{2}} \det(\mathcal{K})^{\frac{1}{2}}} \exp \left[ -\frac{1}{2} (\mathbf{Y}^\top \mathcal{K}^{-1} \mathbf{Y}) \right] \quad (6)$$

with the square covariance matrix  $\mathcal{K}$

$$\mathcal{K} = \mathcal{K}(\mathbf{X}; \mathbf{X}) = \begin{bmatrix} \Sigma(\mathbf{x}_1; \mathbf{x}_1) & \Sigma(\mathbf{x}_1; \mathbf{x}_2) & \dots & \Sigma(\mathbf{x}_1; \mathbf{x}_N) \\ \Sigma(\mathbf{x}_2; \mathbf{x}_1) & \Sigma(\mathbf{x}_2; \mathbf{x}_2) & \dots & \Sigma(\mathbf{x}_2; \mathbf{x}_N) \\ \vdots & \vdots & \dots & \vdots \\ \Sigma(\mathbf{x}_N; \mathbf{x}_1) & \Sigma(\mathbf{x}_N; \mathbf{x}_2) & \dots & \Sigma(\mathbf{x}_N; \mathbf{x}_N) \end{bmatrix} \in \mathcal{R}^{N \times N} \quad (7)$$

Maximum likelihood optimising the properties of the GPs prior used to generate new predictive distributions by looking for proper candidate that maximises the probability of the training data. The values of the parameters depend on the training data quality, and it is not easy to select their prior distribution. For this reason, mostly a uniform prior distribution is selected and the following assumption is used

$$\mathcal{P}(\boldsymbol{\theta} | \mathbf{X}; \mathbf{Y}) \propto \mathcal{P}(\mathbf{Y} | \mathbf{X}; \boldsymbol{\theta}) \quad (8)$$

which states that the maximum a posteriori estimate of the hyperparameters equals the maximum marginal likelihood estimate. Combining (6) with (8) and taking advantage of the monotonic property of the logarithm functions, the objective function to be minimised is written as

$$-\mathcal{L}(\boldsymbol{\theta}) = \frac{N}{2} \ln 2 + \frac{1}{2} \ln(\det \mathcal{K}) + \frac{1}{2} \mathbf{Y}^\top \mathcal{K}^{-1} \mathbf{Y} \quad (9)$$

where  $\mathcal{L}(\boldsymbol{\theta}) = \mathcal{P}(\mathbf{Y} | \mathbf{X}; \boldsymbol{\theta})$ . Finally, the optimal set of parameters  $\boldsymbol{\theta}_{\text{opt}}$  is provided by solving the following nonlinear and non-convex optimisation problem

$$\boldsymbol{\theta}_{\text{opt}} = \min \mathcal{L}(\boldsymbol{\theta}) \quad (10)$$

Once the regressors, covariance function, mean function and parameters are selected, the model is validated by measuring the accuracy of the training  $\mathbf{D}_{\text{train}}$  and test  $\mathbf{D}_{\text{test}}$  data sets using different metrics. Below, we provide standard metrics to validate models in our numerical example and refer [30] to the reader for an overview of the bench of accuracy measuring metrics.

The normalised root mean squared error (nrmse) – the measure that normalises the root mean squared error between the mean of the model’s output and the measured output of the process by the maximum difference of the output values of the training data set

$$\text{nrmse} = \sqrt{\frac{1}{N} \frac{\sum_{i=1}^N (y_i - \hat{y}(\mathbf{x}_i))^2}{(\mathbf{Y}_{\max} - \mathbf{Y}_{\min})^2}} \quad (11)$$

Mean standardised log loss (msll) helps us better understand how big model’s  $\sigma^2$  varies and is obtained by subtracting the mean prediction of the model from true measurements and dividing by predicted variance

$$\text{msll} = \frac{1}{2N} \sum_{i=1}^N \left[ \ln \sigma^2(\mathbf{x}_i) + \frac{(y_i - \hat{y}(\mathbf{x}_i))^2}{2\sigma^2(\mathbf{x}_i)} \right] \quad (12)$$

### 4.3. Predictive model

The GPs can be utilised as a prior probability distribution in Bayesian inference [30], allowing function regression to perform. A new given test sample  $\mathbf{x}_? \in \mathcal{X}$  is combined with existing training samples based

on the Bayesian framework to obtain a posterior distribution for  $\mathbf{y}_?$   $\in \mathcal{Y}$ . Hence, we define the predictive distribution of  $\mathbf{y}_?$  conditioned on  $\mathbf{D}; \mathcal{K}; \mathbf{x}_?; \theta_{\text{opt}}$  as follows

$$\mathcal{P}(\mathbf{y}_? | \mathbf{D}; \mathcal{K}; \mathbf{x}_?; \theta_{\text{opt}}) = \frac{\mathcal{P}([\mathbf{Y}; \mathbf{y}_?] | \mathcal{K}; \mathbf{X}; \mathbf{x}_?; \theta_{\text{opt}})}{\mathcal{P}(\mathbf{Y} | \mathcal{K}; \mathbf{X}; \theta_{\text{opt}})} \quad (13)$$

After adopting the conditional probability functions from (6) for  $\mathcal{P}([\mathbf{Y}; \mathbf{y}_?] | \mathcal{K}; \mathbf{X}; \mathbf{x}_?; \theta_{\text{opt}})$  and  $\mathcal{P}(\mathbf{Y} | \mathcal{K}; \mathbf{X}; \theta_{\text{opt}})$ , the joint multivariate predictions for the batch of random variables  $[\mathbf{Y}; \mathbf{y}_?] = [\mathbf{y}_1; \dots; \mathbf{y}_N; \mathbf{y}_?] \in \mathcal{Y}$  are written as

$$\begin{bmatrix} \mathbf{y}_1 \\ \mathbf{y}_2 \\ \vdots \\ \mathbf{y}_N \\ \mathbf{y}_? \end{bmatrix} \sim \mathcal{GP} \left( \begin{bmatrix} (\mathbf{x}_1) \\ (\mathbf{x}_2) \\ \vdots \\ (\mathbf{x}_N) \\ ?(\mathbf{x}_?) \end{bmatrix}; \begin{bmatrix} \mathcal{K}\mathcal{K}_? \\ \mathcal{K}_?^T \quad ? \end{bmatrix} \right) \quad (14)$$

where the covariance matrices  $\mathcal{K}_? = [(\mathbf{x}_1; \mathbf{x}_?); \dots; (\mathbf{x}_N; \mathbf{x}_?)]^T \in \mathbb{R}^{N+1}$  is the vector of similarity measure between the training samples and the samples and  $? = (\mathbf{x}_?; \mathbf{x}_?) \in \mathbb{R}$  is the self-covariance of the test sample.

From (14), we can deduce that the Gaussian prediction  $\mathbf{y}_?$  for the new input  $\mathbf{x}_?$  with the mean  $?(\mathbf{x}_?)$  and the variance  $?^2(\mathbf{x}_?)$  is given as follows

$$\mathbf{y}_? = \mathbf{y}_{GP}(\mathbf{x}_?) \sim \mathcal{GP}(\mathbf{y}_{GP}(\mathbf{x}_?); \mathbf{y}_{GP}^2(\mathbf{x}_?) | \theta_{\text{opt}}) \quad (15)$$

$$\mathbf{y}_{GP}(\mathbf{x}_?) = \mathbf{y}(\mathbf{x}_?) + \mathcal{K}_?^T \mathcal{K}^{-1} (\mathbf{Y} - \mathbf{X}) \quad (16)$$

$$\mathbf{y}_{GP}^2(\mathbf{x}_?) = ? - \mathcal{K}_?^T \mathcal{K}^{-1} \mathcal{K}_? \quad (17)$$

The GPs model learning algorithm and the summary of this section are highlighted in Algorithm 1.

**Input:** training data  $\mathbf{D}_{\text{train}}$ , test data  $\mathbf{D}_{\text{test}}$ , validating metric  $\rho$ , training data accuracy threshold  $\varepsilon_{\text{train}}$  and test data accuracy threshold  $\varepsilon_{\text{test}}$ .

**Output:**  $\mathbf{y}_{GP}(\mathbf{x}) \sim \mathcal{GP}(\mu(\mathbf{x}), \sigma^2(\mathbf{x}) | \theta_{\text{opt}})$

**while**  $\rho_{\text{train}} > \varepsilon_{\text{train}}$  and  $\rho_{\text{test}} > \varepsilon_{\text{test}}$  **do**

    set  $l_y, l_u, l_d$

    assign prior GPs model  $\mathbf{y}_{GP}(\mathbf{x}_i) \sim \mathcal{GP}(\mu(\mathbf{x}_i), \sigma^2(\mathbf{x}_i) | \theta_{\text{ig}})$   $i = 1, 2, \dots, N$

    compute  $\mathcal{K}$

    solve minimisation problem (10) and obtain  $\theta_{\text{opt}}$

    measure  $\rho_{\text{train}}$  and  $\rho_{\text{test}}$  based on  $\mathbf{y}_{GP}(\mathbf{x}) \sim \mathcal{GP}(\mu(\mathbf{x}), \sigma^2(\mathbf{x}) | \theta_{\text{opt}})$

**end**

**Algorithm 1.** GPs-based MPC at a time step  $t$

## 5. Building indoor thermal comfort

This section deals with the optimal control problem for building indoor thermal comfort using MPC methodology applied to stochastic dynamic processes. For this purpose, a GPs model is used to learn the building model and integrated into the MPC scheme to design a robust control using variance information of the GPs model.

### 5.1. MPC theory

**Definition 2.** Consider the following classic MPC optimisation problem with input and output constraints

$$\begin{aligned}
 \min_{\mathbf{U}} \quad & \sum_{t=0}^{N_p-1} \ell(\mathbf{y}_{+1+t}, \mathbf{x}_{+1+t}, \mathbf{u}_{+t}) \\
 \text{s.t.} \quad & \mathbf{x}_{+1+t} = f(\mathbf{x}_{+t}, \mathbf{u}_{+t}, \mathbf{d}_{+t}) \quad \in \mathbb{I}_0^{N_p-1} \\
 & \mathbf{u}_{+t}^{\min} \leq \mathbf{u}_{+t} \leq \mathbf{u}_{+t}^{\max} \quad \in \mathbb{I}_0^{N_p-1} \\
 & \mathbf{y}_{+t} = \mathbf{C}\mathbf{x}_{+t} + \mathbf{v}_{+t} \quad \in \mathbb{I}_1^{N_p} \\
 & \mathbf{y}_{+t}^{\min} \leq \mathbf{y}_{+t} \leq \mathbf{y}_{+t}^{\max} \quad \in \mathbb{I}_1^{N_p}
 \end{aligned} \tag{18}$$

where  $t$  is the current time instant,  $N_p$  is the prediction horizon,  $\mathbb{I}_a^b$  is the set of all integers in the interval  $[a; b]$ ,  $\mathbf{U} = [\mathbf{u}_0; \dots; \mathbf{u}_{N_p-1}]$  is the sequence of manipulated variables  $\mathbf{u}_{+t} \in \mathbb{R}^{n_u}$  to optimise,  $\mathbf{x}_{+t} \in \mathbb{R}^{n_x}$  is the state vector at  $t$ -steps ahead,  $\mathbf{y}_{+t} \in \mathbb{R}^{n_y}$  is the output vector and  $\mathbf{v}_{+t} \in \mathbb{R}^{n_y}$  is the corresponding disturbing noise,  $\mathbf{d}_{+t} \in \mathbb{R}^{n_d}$  is a disturbance vector affecting the prediction model described by  $f: \mathbb{R}^{n_x} \times \mathbb{R}^{n_u} \times \mathbb{R}^{n_d} \rightarrow \mathbb{R}^{n_x}$ ,  $\ell: \mathbb{R}^{n_y} \times \mathbb{R}^{n_x} \times \mathbb{R}^{n_u} \times \mathbb{R}^{n_y} \rightarrow \mathbb{R}_0$  are convex stage cost functions.


MPC is a control technique that selects optimal control action based on the future state predictions of the system model. Optimal control actions are calculated by solving an optimisation problem so that an objective function is minimised and constraints are satisfied in every step of a controlled system. Then the only first sample of the commanded inputs is applied to the system as its optimal input. This process is repeated all over again to calculate the control signal in every step [8]. The development of the model to predict the outputs/states in the MPC objective function is the most primary and time-consuming task of MPC design. However, the rapid development of machine learning techniques and the increasing data accessibility in buildings have empowered the study of data-driven models, as we discuss below, due to their simplicity, high level of automation, and low development engineering effort [2, 33].

### 5.2. GP-based MPC solution algorithm

Building climate control must balance three conflicting demands: energy efficiency, cost, and thermal comfort. MPC is an optimal control method to design control law by minimizing a performance index while handling these demands. However, designing accurate building energy/temperature models is the cornerstone to developing MPC for whole building operation and control due to the presence of external disturbances. This issue can be alleviated by including the variance term in the MPC optimisation objec-



tive enabling the design of a robust controller thanks to the availability of uncertainty prediction in GPs modelling. The MPC scheme based on the GPs model is illustrated in Figure 1.



**Figure 1.** The schematic representation of the building thermal comfort control system using the GPs-based MPC controller at a  $\tau$ -step ahead from time  $t$

One of the most important constraints for the building climate control optimisation problem is human thermal comfort. There are two main methods to introduce this constraint to the problem: predicted mean vote [14] and thermal bounds [11]. Treating MPC with the former type as a constraint or objective function increases the computational burden of the optimisation problem. For this reason, we consider the latter as a thermal constraint with linear upper and lower bounds in our proposed control problem. We are interested in the use of GPs for predicting the room(s) air temperature  $\mathbf{y}$  as a function of the previous temperature measurements, weather forecast disturbances  $\mathbf{d}$  (solar radiation, outside air temperature and internal heat gains) and manipulated variables  $\mathbf{u}$ . The control task is to keep the room temperature within a predefined comfort range by commanding a set of different actuators  $\mathbf{u}$  such as heating, cooling, ventilation and air conditioning. The goal is to select the optimal control inputs automatically using GPs-based MPC while satisfying the comfort requirements and minimising energy costs coming from manipulated set points. GPs model-based MPC optimisation problem is defined as follows

$$\begin{aligned}
 \min_{\mathbf{U}; E} \quad & \sum_{i=0}^{N_p-1} \|\mathbf{y}_{t+1+jt}\|_{Q_y}^2 + \|\mathbf{x}_{t+1+jt}\|_Q^2 + \|\mathbf{u}_{t+jt}\|_{Q_u}^2 \\
 \text{s.t.} \quad & \mathbf{x}_{t+jt} = \begin{bmatrix} \mathbf{y}_{t+jt} \dots \mathbf{y}_{t+jt} & \mathbf{y}_{t+jt} \mathbf{u}_{t+jt} \dots \mathbf{u}_{t+jt} & \mathbf{u}_{t+jt} & \mathbf{d}_{t+1+jt} \dots \mathbf{d}_{t+1+jt} \end{bmatrix}; \quad \in \mathbb{I}_0^{N_p-1} \\
 & \mathbf{y}_{t+1+jt} = \mathbf{f}_{t+1+jt}(\mathbf{x}_{t+jt}) + \mathcal{K}_{t+1+jt}^T \mathcal{K}_t^{-1} (\mathbf{Y}_t - \mathbf{f}_t(\mathbf{X}_t)); \quad \in \mathbb{I}_0^{N_p-1} \\
 & \mathbf{x}_{t+1+jt} = \mathbf{g}_{t+1+jt}(\mathbf{x}_{t+jt}) - \mathcal{K}_{t+1+jt}^T \mathcal{K}_t^{-1} \mathcal{K}_{t+jt}; \quad \in \mathbb{I}_0^{N_p-1} \\
 & \mathbf{u}_{t+jt}^{\min} \leq \mathbf{u}_{t+jt} \leq \mathbf{u}_{t+jt}^{\max}; \quad \in \mathbb{I}_0^{N_p-1} \\
 & \mathbf{y}_{t+jt}^{\min} \leq \mathbf{y}_{t+jt} \leq \mathbf{y}_{t+jt}^{\max}; \quad \in \mathbb{I}_1^{N_p}
 \end{aligned} \tag{19}$$

where  $\|s\|_Q^2 = s^T Q_s$  is a weighted quadratic norm, and  $Q_y; Q; Q_u$  are corresponding positive definite matrices. The summary of GPs-based MPC scheme is given in the Algorithm 2, while Figure 2 illustrates the corresponding flowchart of the proposed optimal control law.

**Input:** Training data:  $\mathbf{D}_t = \{\mathbf{X}_t, \mathbf{Y}_t\}$ , auto-regressive lags:  $l_y, l_u, l_d$ , GPs model

$$\Phi_{GP}(\mathbf{x}_t) \sim \mathcal{GP}(\mu_t(\mathbf{x}_t), \sigma_t^2(\mathbf{x}_t) | \theta_{opt}).$$


**Output:**  $\mathbf{u}_t$

calculate the matrices  $\mathcal{K}_t^{-1}$  and  $\mu_t(\mathbf{X}_t)$

solve MPC problem (19) online for  $\mathbf{u}_t, \dots, \mathbf{u}_{t+N_h-1}$

apply only  $\mathbf{u}_t$  to the building

**Algorithm 2.** GPs-based MPC at a time step  $t$



**Figure 2.** The flowchart of the GPs-based MPC control strategy at a time  $t$

## 6. Numerical example

In this section, we demonstrate the potential of the proposed strategy on a simulation example using a simplified version of the building given in [17]. We consider the following discrete nonlinear system

$$\begin{cases} \mathbf{x}_{t+1} = \mathbf{A}\mathbf{x}_t + \mathbf{B}\mathbf{u}_t + \mathbf{E}\mathbf{d}_t \\ \mathbf{y}_t = \mathbf{C}\mathbf{x}_t + \mathbf{v}_t \end{cases} \quad (20)$$

with

$$\mathbf{A} = \begin{bmatrix} 0.8511 & 0.0541 & 0.0707 \\ 0.1293 & 0.8635 & 0.0055 \\ 0.0989 & 0.0032 & 0.7541 \end{bmatrix}; \quad \mathbf{B} = \begin{bmatrix} 0.070 \\ 0.006 \\ 0.004 \end{bmatrix}$$

$$\mathbf{E} = \begin{bmatrix} 0.02221 & 0.00018 & 0.0035 \\ 0.00153 & 0.00007 & 0.0003 \\ 0.10318 & 0.00001 & 0.0002 \end{bmatrix}; \quad \mathbf{C} = \begin{bmatrix} 0 \\ 1 \\ 0 \end{bmatrix}^T$$

The primary purpose of the control task is to achieve temperature  $\mathbf{y}$  comfort while minimising energy consumption by manipulating the control signal  $\mathbf{u}$ . To solve both classic MPC (18) and GPs-based MPC (19) problems, we choose the weights as  $Q_y = 1$ ,  $Q = 1$ ,  $Q_u = 1$  and use the values of

variables frequently used throughout this paper and summarised in Table 1 for this particular problem. We solve nonlinear optimisation problems associated with both MPCs using the IPOPT [6] algorithm in the CasADi framework [5] and execute all simulations in MATLAB 2018b on a machine equipped with an Intel Core i5-5200U (2.7 GHz) processor.

**Table 1.** Meaning and values of the variables used in control optimisation problems

Variable	Description	Control setup
$\mathbf{x}$ , C	indoor wall/room/outside wall temperatures	states
$\mathbf{u}$ , W/m <sup>2</sup>	heating set-point	control input
$\mathbf{d}$ , C, W/m <sup>2</sup>	outside temperature, solar radiation, internal heat gain	state disturbances
$\mathbf{u}^{\min} = 0$ , W/m <sup>2</sup>	minimum heating capacity	input constraint
$\mathbf{u}^{\max} = 30$ , W/m <sup>2</sup>	maximum heating capacity	input constraint
$\mathbf{y}$ , C	room temperature	output
$\mathbf{y}^{\min} = 21$ , C	lower comfort boundary	output constraint
$\mathbf{y}^{\max} = 23.5$ , C	upper comfort boundary	output constraint
$\mathbf{v} \sim \mathcal{N}(0, 0.02)$ , C	measurement Gaussian noise	output disturbance
$\epsilon$ , C	comfort band violation	slack

To learn the GPs model in (15), we generate the data of  $M = 2000$  samples as follows: (i) the control signal  $\mathbf{u}$  is frozen for three consecutive time steps with uniform distribution in the magnitude between  $\mathbf{u}^{\min}$  and  $\mathbf{u}^{\max}$  as specified in Table 1, (ii) obtained signals are applied to the building model described by (20), and the corresponding measurements are collected. We use  $M_{\text{train}} = 0.6M$  samples for learning the parameters of the GPs model and  $M_{\text{test}} = 0.4M$  test samples used to assess the performance of the specified model. We validate the GPs model by measuring the prediction accuracy using the commonly used nrmse and MSLI provided in [30]. GPs models with zero mean are common in practice, so we set  $\mu = 0$  and look for a proper covariance function candidate by considering squared exponential se in (21a) and rational quadratic rq in (21b) covariance functions with several combinations of corresponding autoregressive lags. The IPOPT [6] optimisation algorithm is implemented to solve problem (10). We choose the composite covariance function in (21c) with  $l_y = 2$ ,  $l_u = 2$ , and  $l_d = 0$  as it performs better accuracy compared to other candidates (Table 2).

$$f_1(\mathbf{x}; \mathbf{x}^{\theta}) = \bar{r}_1 \exp \left( -\frac{1}{2} \sum_{s=1}^n \frac{(\mathbf{x} - \mathbf{x}^{\theta})^2}{\frac{2}{1;s}} \right) \quad (21a)$$


$$f_2(\mathbf{x}; \mathbf{x}^{\theta}) = \bar{r}_2 \exp \left( -\frac{1}{2} \sum_{s=1}^n \frac{(\mathbf{x} - \mathbf{x}^{\theta})^2}{\frac{2}{2;s}} \right) \quad (21b)$$

$$f(\mathbf{x}; \mathbf{x}^{\theta}) = f_1(\mathbf{x}; \mathbf{x}^{\theta}) + f_2(\mathbf{x}; \mathbf{x}^{\theta}) \quad (21c)$$

**Table 2.** GPs modelling accuracy results (nrmse/msli) on the training data for different autoregressive lags and covariance functions (se – squared exponential, rq – rational quadratic)


Covariance function	Autoregressive lags				
	$l_y=3, l_u=2, l_d=1$	$l_y=2, l_u=2, l_d=0$	$l_y=2, l_u=1, l_d=1$	$l_y=1, l_u=1, l_d=1$	$l_y=1, l_u=1, l_d=0$
se	0.061/-1.770	0.002/-4.124	0.017/-2.946	0.045/-1.122	0.108/-1.360
se + rq	0.045/-1.910	0.001/-4.829	0.024/-3.846	0.035/-1.208	0.096/-1.642
rq	0.061/-1.770	0.115/-1.284	0.097/-2.556	0.067/-1.520	0.137/-1.595

Figure 3 illustrates trajectories and corresponding uncertainty regions predicted by the GPs model for applied control signals, where the mean values are indistinguishable from the true ones. The prediction for the test data is depicted in the left top corner of Figure 4. Moreover, the robustness of the chosen GPs model is tested with different Gaussian noises  $\mathbf{v}$  and the corresponding trajectory forecasts are demonstrated in Figure 4, where one can see that the uncertainty region enlarges as the noise variance increases. For the sake of better visualisation, we cut the first 200 samples off in all figures.



**Figure 3.** The prediction accuracy of the GPs model for the training data:

a) top plot draws the true (blue), the predicted mean  $\mu$  (yellow) and 95% confidence intervals  $\mu + 2\sigma$  (grey) values, while the bottom plot shows the absolute error  $e$  between true and predicted values, b) control signal




**Figure 4.** Effects of introducing different Gaussian noises to the system output:

a)  $\mathbf{v} \sim \mathcal{N}(0, 0.02)$ , b)  $\mathbf{v} \sim \mathcal{N}(0, 0.01)$ , c)  $\mathbf{v} \sim \mathcal{N}(0, 0.03)$ , d)  $\mathbf{v} \sim \mathcal{N}(0, 0.05)$

The classic GPs with  $N_p = 10$  and the GPs-based MPC controllers are tested in simulation by running a temperature from a feasible initial state  $\mathbf{y}_0 = 22$  C and simulation results are obtained for 150 hours. Figure 5 shows that the GPs-based MPC scheme can keep the temperature within the thermal comfort margins and recovers a good closed-loop performance by using the variance prediction preview information to compute the objective function.

## 7. Conclusion

This paper discussed the use of GPs for predictive and probabilistic modelling of a building's complex dynamics for thermal comfort. We learned a GPs model that predicts a room air temperature as output



**Figure 5.** The closed-loop performances of classic MPC and GPs-based MPC law: a) room temperature, b) heating input

for a given input vector which is the combination of the previous temperature measurements, weather forecast disturbances such as solar radiation, outside air temperature and internal heat gains, and manipulated heating set-point. MPC strategy based on the GPs model was implemented to obtain optimal heating set-points providing user-predefined min-max thermal comfort. We exploited the GPs model's mean prediction for the room temperature and used the corresponding provided uncertainty bounds in the MPC objective function not to lose the desired performance as compared with classic MPC law in simulation results. Besides this, GPs-based MPC achieved the desired closed-loop performance with a shorter prediction horizon and converged to the optimal solution in lighter computation time as compared to other classic MPC strategies mentioned in this work. Our future work will be focused on designing robust decision-making of the GPs-based MPC scheme if an uncertain weather forecast is provided and one of the measuring sensors is broken.

## Acknowledgement

The authors are grateful to Turin Polytechnic University in Tashkent for providing access to downloading sources for this research and the necessary tools to run simulations.

## References

- [1] ABDUFATTOKHOV, S., IBRAGIMOVA, K., AND GULYAMOVA, D. The applicability of machine learning algorithms in predictive modeling for sustainable energy management. In *Forthcoming Networks and Sustainability in the IoT Era*, F. Al-Turjman and J. Rasheed, Eds., Springer International Publishing, Cham, 2022, pp. 379–391.
- [2] ABDUFATTOKHOV, S., IBRAGIMOVA, K., GULYAMOVA, D., AND TULAGANOV, K. Gaussian processes regression based energy system identification of manufacturing process for model predictive control. *International Journal of Emerging Trends in Engineering Research* 8, 9 (2020), 4927–4932.
- [3] ABDUFATTOKHOV, S., AND MUHIDDINOV, B. Probabilistic approach for system identification using machine learning. In *2019 International Conference on Information Science and Communications Technologies (ICISCT)*, IEEE, Tashkent, 2019, pp. 1–4.
- [4] AFRAM, A., AND JANABI-SHARIFI, F. Theory and applications of HVAC control systems - a review of model predictive control (MPC). *Building and Environment* 72 (2014), 343–355.
- [5] ANDERSSON, J. A. E., GILLIS, J., HORN, G., RAWLINGS, J. B., AND DIEHL, M. CasADi: a software framework for nonlinear optimization and optimal control. *Mathematical Programming Computation* 11 (2019), 1–36.
- [6] A. WÄCHTER, AND BIEGLER, L. T. On the implementation of a primal-dual interior point filter line search algorithm for large-scale nonlinear programming. *Mathematical Programming* 106, 1 (2006), 25–57.

- [7] AŽMAN, K., AND KOČIJAN, J. Application of Gaussian processes for black-box modelling of biosystems. *ISA Transactions* 46, 4 (2007), 443–457.
- [8] BORRELLI, F., BEMPORAD, A., AND MORARI M. *Predictive control for linear and hybrid systems*. Cambridge University Press, 2017.
- [9] BRIK, B., ESSEGHIR, M., MERGHEM-BOULAHIA, L., AND SNOUSSI, H. ThermCont: A machine Learning enabled Thermal Comfort Control Tool in a real time. In *2019 15th International Wireless Communications and Mobile Computing Conference (IWCMC)*, Tangier, Morocco, 2019, IEEE, pp. 294–300.
- [10] BRIK, B., ESSEGHIR, M., MERGHEM-BOULAHIA, L., AND SNOUSSI, H. An IoT-based deep learning approach to analyse indoor thermal comfort of disabled people. *Building and Environment* 203, (2021), 108056.
- [11] CHEN, X., WANG, Q., AND SREBRIC, J. A data-driven state-space model of indoor thermal sensation using occupant feedback for low-energy buildings. *Energy and Buildings* 91, (2015), 187–198.
- [12] DOUNIS, A. I., AND CARAISCOS, C. Advanced control systems engineering for energy and comfort management in a building environment—a review. *Renewable and Sustainable Energy Reviews* 13, 6-7 (2009), 1246–1261.
- [13] FANG, X., GONG, G., LI, G., CHUN, L., PENG, P., LI, W., SHI, X., AND CHEN, X. Deep reinforcement learning optimal control strategy for temperature setpoint real-time reset in multi-zone building HVAC system. *Applied Thermal Engineering* 212, (2022), 118552.
- [14] FANGER, P. O. Thermal comfort. analysis and applications in environmental engineering. *Thermal comfort. Analysis and applications in environmental engineering*. Danish Technical Press, Copenhagen, Denmark, 1970.
- [15] FAYYAZ, M., FARHAN, A. A., AND JAVED, A. R. Thermal comfort model for HVAC buildings using machine learning. *Arabian Journal for Science and Engineering* 47 (2022), 2045–2060.
- [16] GAUTHIER, S. The role of environmental and personal variables in influencing thermal comfort indices used in building simulation. In *Proceedings of BS2013: 13th Conference of International Building Performance Simulation Association, Chambéry, France, August 26-28 (2013)*, IBPSA, pp. 2320–2325.
- [17] GWERDER, M., AND TÖDTLI, J. Predictive control for integrated room automation. In *8th REHVA World Congress Clima 2005 Lausanne, 9-12 October 2005 “Experience the Future of Building Technologies”*, 2005, 1–6.
- [18] HALAWA, E., AND HOOF, J. V. The adaptive approach to thermal comfort: A critical overview. *Energy and Buildings* 51 (2012), 101–110.
- [19] HENZE, G. P., KALZ, D. E., FELSMANN, C., AND KNABE, G. Impact of forecasting accuracy on predictive optimal control of active and passive building thermal storage inventory. *HVAC&R Research* 10, 2 (2004), 153–178.
- [20] HSIAO, Y. H. Household electricity demand forecast based on context information and user daily schedule analysis from meter data. *IEEE Transactions on Industrial Informatics* 11, 1 (2015), 33–43.
- [21] JOVANOVIĆ, R. Ž., SRETENOVIĆ, A. A., AND ŽIVKOVIĆ, B. D. Ensemble of various neural networks for prediction of heating energy consumption. *Energy and Buildings* 94 (2015), 189–199.
- [22] KOČIJAN, J. *Modelling and control of dynamic systems using Gaussian process models*, Springer International Publishing, Cham, 2016.
- [23] KUMAR, T. M. S., AND KURIAN, C. P. Real-time data based thermal comfort prediction leading to temperature setpoint control. *Journal of Ambient Intelligence and Humanized Computing*, (2022).
- [24] KUSIAK, A., LI, M., AND ZHANG, Z. A data-driven approach for steam load prediction in buildings. *Applied Energy* 87, 3 (2010), 925–933.
- [25] LI, Y., O’NEILL, Z., ZHANG, L., CHEN, J., IM, P., AND DEGRAW, J. Grey-box modeling and application for building energy simulations - A critical review. *Renewable and Sustainable Energy Reviews* 146 (2021), 111174.
- [26] LIANG, J., AND DU, R. Thermal comfort control based on neural network for HVAC application. In *Proceedings of 2005 IEEE Conference on Control Applications, 2005. CCA 2005.*, Toronto, 2005, IEEE, pp. 819–824.
- [27] LIU, Y., WANG, W., AND GHADIMI, N. Electricity load forecasting by an improved forecast engine for building level consumers. *Energy* 139 (2017), 18–30.
- [28] LUTE, P. J. *The use of predictions in temperature control in buildings. A passive climate system application*. PhD thesis, Delft University of Technology, 1992.
- [29] OLDEWURTEL, F., PARISIO, A., JONES, C. N., GYALISTRAS, D., GWERDER, M., STAUCH, V., LEHMANN, B., AND MORARI, M. Use of model predictive control and weather forecasts for energy efficient building climate control. *Energy and Buildings* 45 (2012), 15–27.
- [30] RASMUSSEN, C. E., AND WILLIAMS, C. K. I. *Gaussian processes for machine learning*. MIT Press, Cambridge, MA, 2006.
- [31] SCHIRRE, A., BRANDSTETTER, M., LEOBNER, I., HAUER, S., AND KOZEK, M. Nonlinear model predictive control for a heating and cooling system of a low-energy office building. *Energy and Buildings* 125 (2016), 86–98.
- [32] SERALE, G., FIORENTINI, M., CAPOZZOLI, A., BERNARDINI, D., AND BEMPORAD, A. Model Predictive Control (MPC) for enhancing building and HVAC system energy efficiency: Problem formulation, applications and opportunities. *Energies* 11, 3 (2018), 631.
- [33] SMARRA, F., JAIN, A., DE RUBEIS, T., AMBROSINI, D., D’INNOCENZO, A., AND MANGHARAM, R. Data-driven model predictive control using random forests for building energy optimization and climate control. *Applied Energy* 226 (2018), 1252–1272.
- [34] SOLAK, E., MURRAY-SMITH, R., LEITHEAD, W. E., LEITH, D. J., AND RASMUSSEN, C. E. Derivative observations in Gaussian process models of dynamic systems. In *Advances in Neural Information Processing Systems 15. Proceedings of the 2002 Conference*, S. Becker, Thrun S. and Obermayer K., Eds., MIT Press, Cambridge, MA, 2003, pp. 1057–1064.

- 
- [35] SUN, G., JIANG, C., WANG, X., AND YANG, X. Short-term building load forecast based on a data mining feature selection and LSTM-RNN method. *IEEE Transactions on Electrical and Electronic Engineering* 15, 7 (2020), 1002–1010.
  - [36] THOMPSON, K. R. *Implementation of Gaussian process models for non-linear system identification*. PhD thesis, University of Glasgow, 2009.
  - [37] WANG, J., AND ZHAO, T. Event-driven online decoupling control mechanism for the variable flow rate HVAC system based on the medium response properties. *Building and Environment* 218 (2022), 109104.
  - [38] WANG, Y., OCAMPO-MARTÍNEZ, C., PUIG, V., AND QUEVEDO, J. Gaussian-process-based demand forecasting for predictive control of drinking water networks. In *Critical information infrastructures security. CRITIS 2014*, C. G. Panayiotou, G. Ellinas, E. Kyriakides and M. M. Polycarpou, Eds., vol. 8985 of *Lecture Notes in Computer Science*, 2016, Springer, Cham, pp. 69–80.
  - [39] XU, H., HE, Y., SUN, X., HE, J., AND XU, Q. Prediction of thermal energy inside smart homes using IoT and classifier ensemble techniques. *Computer Communications* 151 (2020), 581–589.
  - [40] ZHANG, L., WEN, J., LI, Y., CHEN, J., YE, Y., FU, Y., AND LIVINGOOD, W. C. A review of machine learning in building load prediction. *Applied Energy* 285 (2021), 116452.